GHG Emission Reduction Record

Artists for Humanity Boston, Massachusetts, U.S.A. October 1, 2004 – September 30, 2005

> Created March 2006 by **ICBE** Gainesville, Florida, U.S.A.








Photo by: Richard Mandelkorn

Summary

In April 2005, Artists for Humanity—a non-profit educational group in Boston, MA—commissioned ICBE to create a greenhouse gas (GHG) reduction record based on the energy performance characteristics of their main building located at 100 West Second Street in South Boston's Waterfront.

The 23,500 square foot structure—named EpiCenter—is a high-performance, industrial-style, glass and steel building, incorporating a variety of sustainable designs, such as walls that provide passive heating and cooling, super insulation, maximum utilization of daylight, and a 48 kW DC rooftop photovoltaic array. Construction was completed in the summer of 2004, and Artists moved in September 2004.

Based on utility records for gas, electricity and water consumption, the study found that during Year One of occupancy, EpiCenter consumed about half the electricity and natural gas compared to a group of comparable buildings, and in spite of various water conserving features, consumed nearly three times the baseline amount of water. The reduction in gas and electricity consumption resulted in nearly 50 tCO2 savings.

Method of Analysis

To create the GHG record, a comparison was drawn between the target building on 100 West Second Street and a pool of similar conventional buildings in the same geographic area. The study's original aim was to create a baseline of thirty buildings located in the Boston area with comparable size and occupational patterns. To accomplish this, the Boston Department of Neighborhood Development (DND) created a master list of the 325 commercial buildings that occupy between ten thousand and forty thousand square feet (sf) from the city's Tax Records. This list was then screened for owners who had local Boston addresses, and who appeared, purely from the impression of owner names, easily approachable in case direct contact was necessary. Buildings owned by Hertz Corporation and XYZ Realty in NY were thus eliminated. Without any further qualification, the working list was reduced to ten buildings larger than thirty thousand sf; ten buildings smaller than twenty thousand sf; and ten buildings with exactly or nearly exactly 23,500 sf.

Due to a variety of issues, in only a limited number of instances were the water, electric, and gas records easily available for the selection of thirty addresses, so the sample pool grew smaller. In addition, upon examination of the water records, it became clear that a number of addresses were occasionally unoccupied and were therefore dropped from the list. Collecting utility records using a given specific address was not always successful. A single location can exist under various aliases in different database systems because: the location is large enough to have multiple adresses; the building was once several buildings reconstructed into a single building; or the billing address is different from the address of the service location. After consultation with contact persons at the various utilities, it was also determined that several buildings (especially in the old Boston downtown) which had been fitted with piping, conduits and points of telemetry when services were first introduced, were deemed to have service footprints

inconsistent with the square footage listed in their tax profiles. Thus, as the original list of thirty was not a useful baseline for comparison, it was discarded, and a new approach was devised.

Based on the experiences gained during the first approach, the working list was reassessed using *Google Earth*'s high resolution Boston search feature. One by one, addresses were pulled up, eliminating: buildings in or close to downtown; buildings attached to other buildings; buildings with fewer than two stories; and buildings with multiple tenants in which the taxable square footage was not equal to the buildings' physical square footage. The first ten buildings surviving these criteria became the new baseline group, which was resubmitted to the relevant utilities. The search returned six electric records, four of which showed gas use. Of the same six electric addresses, three water records were returned. The water records were made available in cubic feet per month; natural gas records in one hundred cubic feet per month; and due to privacy issues, electric data was restricted to demand in kilo watt, as opposed to the more desirable consumption figures in kilo watt hours. All the data were reduced to consumption per square foot, with special attention paid to differences in winter and summer patterns.

The new baseline group showed consistent consumption results when viewed annually and when broken down in summer and winter blocks. As anticipated, addresses served by gas and electric showed high use of gas and lower use of electric in the winter due to heating needs, and the reverse in the summer because of cooling needs. The baseline group used about three times more gas in the winter than in the summer; whereas the winter upswing in gas use in the target building was more tempered, likely due to passive warming and effective insulation characteristics. When the number of baseline buildings was reduced to the four that use gas for heating, the winter electric consumption on a per square foot basis was very similar to each other and to the target building. Summer electric consumption, on the other hand, was less by about two-thirds, due to EpiCenter's alternative cooling techniques.

GHG Factors

Electricity - emission rates associated with kWh consumption from the U.S. Environmental Protection Agency's (EPA) Emissions & Generation Resource Database (eGRID) were applied and reflect the emissions generated in the power control area (PCA) of the baseline and target buildings' locations. The database lags a few years in publication, and for CY 2005, year 2000 emission rates were applied. No discounting was factored in to account for distribution and transmission losses, which nominally stand at a bit over 10% for the New England ISO.

Natural Gas - emission values for Natural Gas were sourced from Argonne National Laboratories' Greenhouse Gases, Regulated Emissions, and Energy Use in Transportation Model, commonly known as GREET. The values applied reflect the consumption of the fuel itself, not the energies expended during recovery, processing, and transportation.

Water - emission rates associated with water consumption were not factored in, but an attempt to estimate those will be made during further refinement of the baseline in Year Two.

Conclusion

To attain a higher level of confidence in assessing the true greenhouse gas reduction aspect of the target building at 100 West Second Street, the baseline needs to be refined. Though results found to date are generally consistent with expectations expressed in documentation of the architects and in paperwork generated for the LEED Certification for Sustainable Design at the Platinum Level, the lower than desired number of qualified comparable buildings in the baseline pool, along with a lack of updated readings of the grid-related emissions factors prevailing in CY2005, forces the greenhouse gas reduction profile to build in a 20% probability of error.

Additionally, building occupants require a few seasons to become fully accustomed to the workings of their building, to optimize the various systems available to them, and to settle into a management routine. Therefore, Year Two and Year Three may be much more representative of the long term energy consumption and the resulting emissions trend.

ICBE will address these issues in collaboration with the various utilities in preparation for Year Two of the GHG Emissions Reduction Record. The greenhouse gas emissions profile for EpiCenter, which we can calculate with certainty, as opposed to its greenhouse gas *reduction* profile which needs more definition, comes in at about 35% less then the national average. This is due to the high presence of hydro, biomass and nuclear resources in New England's electric generation resource mix. It also shows that the given parameters of energy consumption per square foot, solar availability, and grid carbon intenstity—the design and systems employed in EpiCenter—in similar climatic conditions elsewhere in the U.S., could lead to around 800 tCO2 reductions per decade, or roughly 4000 tCO2 over the 50 year design life of the building.

For ICBE: Mark van Soestbergen

March 3, 2006 Gainesville, Florida, U.S.A

(Mw) 33

Acknowledgements/References

This report was made possible through the contribution of many hours, phone calls, data sets, emails, anecdotes and corrections of individuals directly and peripherally involved in the EpiCenter project. Below is a short list of the people who volunteered knowledge, help and guidance necessary in assessing the various building related processes.

Artists for Humanity, for proposing this groundbreaking study.

Robert Gehret, <u>bgehret.dnd@ci.boston.ma.us</u>
Joshua Farmer, <u>farmerj@bwsc.org</u>
Margie Sweeney, <u>msweeney@keyspanenergy.com</u>
Joanna Brown, <u>Joanna_brown@nstaronline.com</u>
Patricia Cornelison, <u>cornelison@arrowstreet.com</u>


References


Kelley, Mark E., Cornelison, Patricia. 2005. Artists for Humanity Epicenter: A Successful Model for the Sustainable Design Process. *Orlando: 2005 Solar World Congress*

Born, Kathleen. 2004. Artists for Humanity EpiCenter Opens in South Boston

United States Green Building Council. 2005. *LEED Certified Project Case Study*. Artists for Humanity EpiCenter. Washington: www.usgbc.org

Key figures





Total project cost: \$4,900,000 Cost per square foot: \$208 Grid emission rate: 407 kg CO2 per MWh Grid emissions: 51,864,054 tCO2/yr

Accreditation formula for a Boston, Massachusetts, LEED certified Industrial / Educational building, using New England PCA as a baseline. October, 2004 ~ September, 2005, applying known electric and natural gas values. Style: Emissions Avoidance

Technically, these types of reductions are named Emission Avoidance Units or EAU's. They are characterized by the fact that they advertently influence the load and emissions results

I echnically, these types of reductions a	are named Emission	Avoidance	is of EAU's. They a	re characterized by	the ract that un	The solution of the state of the solution of t	the load and emiss	Sions results		()
National emissions per kWh	<u>Wh</u>	CO2 (kg)	NOX (kg)	SO2 (kg)	CO (kg)	CO (kg) NMVOC'S (kg) CH4 (kg)		N2O (kg)	SF6 (kg)	HG (kg)
	1	0.63151	0.00135	0.00274	0.00015	0.00002	0.00001	0.00001	0.00000	0.00000
of the utility products that the project would have otherwise had to rely on under conventional circumstances.	would have	e otherwise had to rely or	n under conventional	circumstances.						
NE ISO emissions per kWh	Wh	CO2 (kg)	NOX (kg)	SO2 (kg)						HG (kg)
	1	0.40692	0.00068	0.00171						0.00000
NE PCA baseline kWh	ı	CO2(kg)	NOX (kg)	SO2 (kg)						HG (kg)
	86,466	35,185	58.83	148.25		kWh 53.94%	1.85			0.00038
NE baseline CCF										
1(10,260	57,069				NG 43.86%	2.28			
National kWh		CO2 (kg)	NOX (kg)	SO2 (kg)	CO (kg)	CO (kg) NMVOC'S (kg)	CH4 (kg)	N2O (kg)	SF6 (kg)	HG (kg)
98	86,466	54,604	116.37	237.05	237.05 12.969967	1.729328884	0.8646644	0.86466444	0.0475565	0.00000
kWh from grid	46,640	CO2 (kg) 18,979	31.73	79.97						0.00021
kWh from PV					Quick shee	Quick sheet for U.S. National Average 2000	nal Average			
48	48,685	0			grams/lbs	lbs/MWhg	lbs/MWh grams/kWh		Emission	
NG in CCF		$CO2$ $(k\alpha)$			453.59237	1,392.24	631.50853 2 7415123		20 5 20 3	
	4,500	25,031				2.967	1.3458086	. ~	NOx	
						0.0263	1.193E-05		Hg	
Residual oil in gals		CO2 (kg)			ottp://wwv	http://www.epa.gov/airmarkets/egrid/	ets/egrid/			
	0	0			nttp://bioe	http://bioenergy.ornl.gov/papers/misc/energy_conv.html	tpers/misc/er	nergy conv.h	<u>ıtml</u>	
LPG in gals		CO2 (kg)			Quick shee	Quick sheet for New England ISO and PCA 2000	and ISO and	PCA 2000		
	0	0			grams/lbs	lbs/MWh	lbs/MWh grams/kWh	I	Emission	
					453.59237	897.11	406.92225	Ŭ	CO ₂	
Gasoline in gals		CO2 (kg)				3.78	1.7145792		SO ₂	
	0	0				1.5	0.6803886	_	NOx	
						0.0097	4.4E-06		Hg	
Diesel in gals		CO2 (kg)			NStar is ar	NStar is an integral part of the New England ISO & PCA	the New En	gland ISO	& PCA	
	0	0			ottp://wwv	http://www.iso-ne.com/				


afh Boston	CO2 (kg) 44,009	NOX (kg) 31.73	SO2 (kg) 79.97	CO (kg)	NMVOC'S (kg)	CH4 (kg)	N2O (kg)	SF6 (kg)	HG (kg) 0.00021
afh Baseline	CO2 (kg) 92,254	NOX (kg) 58.83	SO2 (kg) 148.25	CO (kg)	NMVOC'S (kg)	CH4 (kg)	N2O (kg)	SF6 (kg)	HG (kg) 0.00038
afh Boston Credit	CO ₂ (kg) 48,245	NOx (kg) 27.09746	SO ₂ (kg) 68.28559						Hg (kg) 0.0001752

 afh
 local average
 national average

 kWh results
 35,185
 54,604

 Natural Gas results
 25,031
 57,069
 57,069

Annual kWh related tCO2 impact of similar buildings



35,185

50,000

40,000 - 30,000 - 20,000 - 10,000 - 0 - 0

70,000 -

18,979

ERC % project holder		ICBE	Discount	Insurance
	20%	2%	20%	5%
ERC's (t)				100%
	33.84	2.42	29.6	2.42
Total				48.340233

local average

ath

1.87	48,245	48,340
GHG rate in kgCO2/ft2/yr	GHG sink rate in tCO2/yr	Total Avoided Emissions

When all baseline uses gas for heating, afh's electric demand in KW (Kilowatt or 1000 watt) shows nearly identical in winter,	as for heating	, afh's electri	ic demand in KV	W (Kilowatt or 1	000 watt) shows ne	arly identical in	winter,				
ST NUM ST NAME ST SUF STATE ZIP CODE GROSS AREA KW Win 2006 KW Sum 2005 1	ST SUF	, wileli basel STATE	ZIP CODE O	SROSS AREA	THE COOLS WITH ACT, AND ATH COOLS USING ARETTALIVE RECTINIQUES. ZIP CODE GROSS AREA KW WIN 2006 KW Sum 2005 KW WIN 2005 KW Sum 2004 KW WIN 2004 KW Sum 2003 KW WIN 2003	Sum 2005 KW N	Win 2005 P	W Sum 2004 KW	/ Win 2004 KW	Sum 2003 KW	Win 2003
BOSTON	ST	₽	02125	20000	28.8	58.4	32.4	54.8	32.4	46.8	31.2
BROOKLINE	۸	٩V	02215	22878	54.0	0.89	54.2	0.69	58.0	76.0	49.0
HARCOURT	ST	MA	02116	10665	21.6	54.0	22.8	49.2	28.0	50.0	24.0
WALNUT	ST		02108	13248	28.0	8.03	23.9	40.6	23.7	50.5	26.4
		average	gross sf total sf per building	66,791 16,698							
		averaç avera	average DMD in KW average DMD per sf		33.1	57.8 0.0035	33.3	53.4	35.5 0.0021	55.8 0.0033	32.7
av	average DMD per sf all buildings over 3 years	. sf all building	s over 3 years	0.0026							
target building target building		avera	DMD in KW average DMD per sf		37.6	25.6	49.6				
	average target buildi.	DMD per sf c ng DMD relat	average DMD per sf over 3 seasons target building DMD relative to baseline	0.0016							
100 West Second	Street			23,500							
197	i in			CT and			VI	About the afh building	Ďi		
		1						More about the afh building	guilding		
- FI					Separation Av. (6) along the		4				
ALLE STATES		100 Worl Second St. E.	The little of th	Visitoatongia	To describe the control of the contr	Info serve texten into					

The target building is a LEED certified, 23,500 square foot multi functional 4 story building, used primarily M-F, 9 to 5pm. The comparison baseline buildings are mainly commercial buildings such as banks, insurance offices etc, with similar occupational patterns.

Electric demand in KW (Kilowatt or 1000 watt), afh's grid demand is a bit over half the baseline average	Kilowatt or	1000 watt)	, afh's grid dem	and is a bit ove	r half the basel	ine average					
ST_NUM ST_NAME	ST_SUF	STATE	ZIP_CODE	GROSS AREA	KW Win 2006	KW Sum 2005	KW Win 2005	KW Sum 2004	KW Win 2004	KW Sum 2003	KW Win 2003
ARLINGTON	ST	MA	02116	16738	12.8	13.2	20.0	12.0	12.0	meter not read	11.4
BOSTON	ST	MA	02125	20000	28.8	58.4	32.4	54.8			31.2
BRADSTON	ST	MA	02118	22932	170.4	86.4	172.8	57.6			177.6
BROOKLINE	۸۷	MA	02215	22878	54.0	68.0	54.2	0.69			49.0
HARCOURT	ST	MA	02116	10665	21.6	54.0	22.8	49.2	28.0	50.0	24.0
WALNUT	ST	MA	02108	13248	28.0	50.8	23.9	40.6			26.4
		averade s	gross sf total average sf per building	106,461							
		average	average DMD in KW		52.6	55.1	54.4	47.2	49.7	56.2	53.3
	average	DMD per	average DMD per sf per season		0.0030	0.0031	0.0031	0.0027	0.0028	0.0032	0.0030
average	DMD per sf a	II buildings	average DMD per sf all buildings over 3 years	0:0030							
target building			DMD in KW		37.6	25.6	49.6				
target building	average	DMD per	average DMD per sf per season		0.0016	0.0011	0.0021				
	average DM	D per sf ov	average DMD per sf over 3 seasons	0.0016							
tar	get building E	MD relativ	target building DMD relative to baseline	53.94%							
100 West Second	Street			23,500							





About the afh building More about the afh building

DMD (demand) is read every time the meter is read, usually once a month. DMD is continuously recalculated as a rolling average of 15 minute increments. In this baseline, Summer demand is based on the August readings and Winter demand on February readings. A more accurate representation of electrical use would employ kWh totals, the goal for Baseline Year 2.

The target building is a LEED certified, 23,500 square foot multi functional 4 story building, used primarily M-F, 9 to 5pm. The comparison baseline buildings are mainly commercial buildings such as banks, insurance offices etc, with similar occupational patterns.

	3 Total 12 months	8,287	713	10,595	12,369		7,991	0.4366		4,500	0.1915			
	GROSS AREA NG Sum 2005 NG Win 2005 NG Total 12 months	7,291	438	8,479	7,851		6,015	0.3286		3,247	0.1382			
average	NG Sum 2005	966	275	2,116	4,518		1,976	0.1080		1,253	0.0533			
alf the baseline	GROSS AREA	16738	22932	22878	10665	73,213 18,303			0.44			0.19	43.86%	23,500
afh uses less than h	ZIP_CODE	02116	02118	02215	02116	gross sf total average sf per building	average usage in CCF	average usage in CCF per sf per season	baseline annual CCF usage per sf	average usage in CCF	average usage in CCF per sf per season	target building CCF usage per sf	e relative to baseline	
(1 CCF = 748.05 gallon),	ST_NAME_SUF STATE	MA	MA	MA	MA	ર્ષ	a	average usage in C	baseline ann	a	average usage in C	target buildi	target building CCF usage relative to baseline	
ubic Feet	ST_NA	ST	ST	¥	ST									Street
Vatural Gas usage in 100 Cubic Feet (1 CCF = 748.05 gallon), afh uses less than half the baseline average	ST_NUM ST_NAME	ARLINGTON	BRADSTON	BROOKLINE	HARCOURT					target building	target building			100 West Second






About the afh building More about the afh building

The target building is a LEED certified, 23,500 square foot multi functional 4 story building, used primarily M-F, 9 to 5pm. The comparison baseline buildings are mainly commercial buildings such as banks, insurance offices etc, with similar occupational patterns.

	Water 2005	5,989	10,340	12,977		9,769	0.5538	32,350	1.3766			
verage	GROSS AREA	16738	22932	13248	52,918 17 639				0.5538	1.38	248.57%	23,500
water usage in cubic Feet (1 CF =7.48 gallon), arn uses more than twice the baseline average	ZIP_CODE	02116	02118	02108	gross sf total	average usage in CF	average usage in CF per sf per year	average usage in CF	average usage in CF per sf per year baseline annual CF usage per sf	target building CF usage per sf	ge relative to baseline	
on), arn uses more tna	IE_SUF STATE	MA	MA	MA	a a	i	average usage		average usage baseline ar	target bui	target building CF usage relative to baseline	
Cr = 7.48 gallo	ST_NAME_SUF	ST	ST	ST								Street
sage in Cubic Feet (1	M ST_NAME	ARLINGTON	BRADSTON	WALNUT				target building	target building			100 West Second
water us	ST_NUM											=

About the afh building More about the afh building





The target building is a LEED certified, 23,500 square foot multi functional 4 story building, used primarily M-F, 9 to 5pm. The comparison baseline buildings are mainly commercial buildings such as banks, insurance offices etc, with similar occupational patterns.

